



PLAN VIEW



ELEVATION



ELEVATION

NOTE:

SUPPLIER SHOULD USE CONCRETE CERTIFIED BY THE PRODUCER TO DEVELOP 5,000# PER SQUARE INCH MINIMUM IN 28 DAYS.

MS-115-A

TRENWA INC.
 1419 ALEXANDRIA PIKE FORT THOMAS, KY. 41075 859-781-0831

SWITCHGEAR MOUNTING BOX		
S & C PME-4 (600 AMPS)		
DATE	PART NO.	
12/22/99	327724	

WEIGHT 2,200# APPROX.

SCALE 3/4"=1'-0"

