




**SLAB C**  
FPC 320-166  
1 EACH




**SLAB A**  
FPC 320-162  
2 EACH




**SLAB B**  
2 REQUIRED



**DETAIL 1**  
SCALE: 3/8" = 1'-0"



**SECTION A-A**  
FPC 320-164



**SECTION B-B**  
320154

**NOTES:**

1. STEEL REINFORCEMENT AS DIMENSIONED IN LID VIEWS TO BE 3/8" REBAR WELDED INTO COMPLETE LOOPS.
2. CONCRETE SHALL BE 4000 PSI MIX OR BETTER AND SHALL SHOW A 3000 PSI COMPRESSIVE STRENGTH AT DELIVERY.
3. DIMENSIONS SHOWN ARE NOMINAL TAPERING TO FACILITATE REMOVAL OF FORMS IS PERMISSIBLE.
4. FORMING CONCRETE STEEL AND ROD PLACEMENT AND CURING SHALL CONFORM TO LATEST APPLICABLE ACI CODE. MAXIMUM TOLERANCE ON DIMENSIONS IS .16".

NO.	DATE	BY	REVISION
<b>TRENWA INC.</b>			
1415 HAZARDEN AVE SCALE: 1" = 1'-0"		FOR TRENWA, INC. #415 DRAWN BY: APPROVED BY:	
DATE: JULY 3, 1999		869-781-0801	
PRECAST MOUNTING BOX FOR 15-167 KVA SINGLE PHASE PAD-MOUNTED TRANSFORMER			DRAWING NUMBER 320154