



PLAN VIEW



ELEVATION



ELEVATION

NOTE:

SUPPLIER SHOULD USE CONCRETE CERTIFIED BY THE PRODUCER TO DEVELOP 5,000# PER SQUARE INCH MINIMUM IN 28 DAYS.

MS-115-A

WEIGHT 2,200# APPROX.

1'-0"

SCALE 3/4"=1'-0"

TRENWA INC.		
1419 ALEXANDRIA PIKE FORT THOMAS, KY. 41075 859-781-0831		
SWITCHGEAR MOUNTING BOX S & C PME-4 (600 AMPS)	DATE 12/22/99	PART NO. 327724