



QA Checklist		Initial
Pre-pour	Dimensions & Mesh	
	Block Outs	
	Inserts, Chairs	
	Lifting Devices	
	Form Oil	
	Form Condition	
Post-pour	Cover > 1/2"	
	Lifting Devices	
	Defects	
	Dimensions	
	Date Manufactured	
	Stenciled	

DUKE NOTES:
 PAD TO BE ABLE TO ADEQUATELY SUPPORT 30,000 LBS.
 2" THICK CONCRETE DIVIDER TO BE PROVIDED FOR PADS IN MECKLENBURG COUNTY, NC.

- NOTES:
1. CONCRETE SHALL HAVE MINIMUM STRENGTH OF 4,000 PSI AT 28 DAYS.
 2. CURING TIME BEFORE DELIVERY SHALL BE A MINIMUM OF 14 DAYS AS LONG AS MINIMUM STRENGTH OF 4,000 PSI HAS BEEN ACHIEVED.
 3. ALL REINFORCING BARS SHALL BE GRADE 60 WITH YIELD STRENGTH OF 60,000 PSI. ALL REINFORCING BARS SHALL BE WELDED OR TIED.

APPROX. 3,934#

Trenwa Inc.		1419 Alexandria Pike
(859) 781-0831		Fort Thomas, KY 41075
SCALE: 1/2"=1'-0"	DRAWN BY: BD	DATE: 12/12/2018
DUKE ENERGY		
THREE PHASE PAD-MOUNTED TRANSFORMER PAD-LARGE		PAD-104x98